



Product Service

CERTIFICATE

No. Z1 18 01 98200 016

Holder of Certificate: Caledonian Cables Limited1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG**Production Facility(ies):**

96882

Certification Mark:**Product:****PVC Insulated Non-sheath cables
Single Core Cable for Switchgear and
Controlgear Wiring****Model(s):****FGD100 1V-K (BS6231 Type BK)
FGD100 1V2-K (BS6231 Type CK)****Parameters:**

Voltage:	600/1000V
Conductors:	Annealed copper conductor, class 5
Insulation:	PVC Type TI1 according to BS EN 50363-3 for cable type BK, and type TI3 according to BS EN 50363-3 for cable type CK
Sizes:	1 x 0.50mm ² to 1 x 240mm ²

Tested according to: BS 6231:2006

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101716507-00**Valid until:** 2023-01-16**Date,** 2018-01-17

(Yi Zhu)

Page 1 of 1

