



CERTIFICATE

No. B 098200 0029 Rev. 00

Caledonian Cables Limited **Holder of Certificate:**

1/F., CMA Building, 64-66 Connaught Road Central,

Central and Western District

HONG KONG

Production Facility(ies):

Certification Mark:

096882



XLPE insulated PVC sheathed cables **Product:**

(BS 5467 600/1000V armoured cables)

FGD300 1RVMAV-R, FGD400 1RVMV-R Model(s):

Conductors: Plain annealed copper wires Parameters:

XLPE, GP8 Insulation:

Extruded layer of polymeric material Bedding: FGD300 1RVMAV-R: armoured with Armour:

aluminium wire;

FGD400 1RVMV-R: armoured with

galvanized steel wire

PVC, Type 9 Sheath:

FGD300 1RVMAV-R: 1C x 1.5mm² to Sizes:

1C x 1000mm²;

FGD400 1RVMV-R: 2C x 1.5mm² to 4C x 400mm²,

5C x 1.5mm2 to 5C x 70mm2

Elin Onlany

BS 5467:2016 Tested according to:

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

64100180485901 Test report no.: 2023-08-15 Valid until:

2018-08-16 (Boris Ouyang) Date,